



Washington Suburban Sanitary Commission Collection System Discharge Written Report

9237256-118-2009

MDE OFFICIAL CONTACTED: NORM GIFFORD

DATA CALLED IN BY: DONNA M FORREST DATE: 11/02/2009 AT 09:00PM

WORK ORDER(S): 9237256 9237173

EST DATE AND TIME SSO BEGAN: 11/02/2009 07:31PM DURATION: 2.48 HRS
DATE AND TIME SSO ENDED: 11/02/2009 10:00PM

SOURCE-OVERFLOWING MH MH08013015 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 6105 57TH AVE 20737-2125
COUNTY/PAGE/GRID: P 5410 C07 TOWN/CITY: RIVERDALE

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 2,976 GAL
THE CREW ARRIVED AND FOUND MANHOLE #015U OVERFLOWING INTO A NEARBY
STORM DRAIN. THE CREW JETTED FROM MANHOLE #014U TO #015U RELIEVING
A HARD UNKNOWN BLOCKAGE.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

PUBLIC ACCESS PUBLIC USE OBSERVED
DRY WEATHER

THE OVERFLOW ENTERED A STORM DRAIN IN THE NORTHEAST BRANCH BASIN. THE
REMAINDER OF THE OVERFLOW WAS FLUSHED BACK INTO THE MANHOLE.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT