



NOTES:

1. RESTRAIN ALL JOINTS ON 6" BLOWOFF PIPING, SEE SPECIFICATIONS.
2. SET VALVE BOX AND MANHOLE RIM TO FINISHED GRADE OR AS SHOWN ON THE DRAWINGS.
3. MANHOLE SHALL BE LOCATED AS SHOWN UNLESS OTHERWISE INDICATED ON THE DRAWINGS.
4. SEE DETAIL W/2.8 FOR V-BIO POLYETHYLENE ENCASEMENT AT MANHOLE INTERFACE.

**HOSE CONNECTION
DETAIL**

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21

M. Hammer
Chief Engineer

STANDARD DETAIL

TYPE "A" BLOWOFF
FOR WATER MAINS
16-INCH TO 30-INCH

W
3.0