

REMOVE MANHOLE FRAME AND COVER AND RETURN TO COMMISSION WAREHOUSE.

EXISTING FINISHED GRADE

REMOVE MANHOLE TO 1'-0" MINIMUM BELOW FINISH GRADE.

FILL MANHOLE SOLID W/LEAN MIX CONCRETE OR FLOWABLE FILL.

FILL ENTIRE LENGTH BETWEEN MANHOLES WITH FLOWABLE FILL. SEE NOTE 1.

FILL ENTIRE LENGTH BETWEEN MANHOLES WITH FLOWABLE FILL. SEE NOTE 1.

NOTE:

1. IF EXISTING SEWER IS REMOVE FROM MANHOLE TO MANHOLE, SEE DETAIL S/3.5

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 7-7-21

*Mike Harmon*  
Chief Engineer

STANDARD DETAIL

MANHOLE AND SEWER  
ABANDONMENT

S  
3.6