



NOTES:

1. REMOTE READING DEVICE IS FOR USE WITH METERS LOCATED IN TRAFFIC AREAS.
2. THIS DEVICE MUST BE LOCATED IN NON-TRAFFIC AREAS. DO NOT LOCATE IN SIDEWALK OR DRIVEWAY.
3. COMPACT BACKFILL AND AGGREGATE BASE AS STRUCTURAL FILL.
4. REMOTE READING CABLE WITHOUT SPLICES THROUGH CONDUIT PIPING.
5. WHEN TWO REMOTE READING DEVICES ARE REQUIRED, USE 11-1/2" DOUBLE RECESS METER FRAME AND COVER.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
Mike Harmon
Chief Engineer

STANDARD DETAIL
REMOTE READING DEVICE

W
5.0e