


NOTES:

1. FIRE HYDRANT HOSE CONNECTION SETTING FOR NON-TRAFFIC AREAS ONLY, DO NOT LOCATE IN SIDEWALK OR DRIVEWAY, UNLESS OTHERWISE NOTED ON THE DRAWINGS.
2. COMPACT BACKFILL AND AGGREGATE BASE AS STRUCTURAL FILL.
3. QUICK-DISCONNECT CAM AND GROOVE FITTINGS SHALL BE BRASS RATED AT 150 PSI AND IN ACCORDANCE WITH US MILITARY SPECIFICATIONS MIL-C-27487/US FEDERAL STANDARD A-A-59326.
4. RESTRAIN ALL JOINTS FROM MJ TEE TO 4" COMPANION FLANGED WITH WEDGE ACTION RESTRAINER GLANDS, SEE SPECIFICATIONS

WASHINGTON SUBURBAN SANITARY COMMISSION	APPROVED: <u>7-26-21</u>  Chief Engineer	STANDARD DETAIL FIRE HOSE CONNECTION FOR FM METER, ULTRASONIC METER, AND DETECTOR CHECK VAULT LAYOUTS	W 5 of
--	---	--	-----------