



NOTES:

1. FIRE HYDRANT HOSE CONNECTION SETTING FOR TRAFFIC AREAS ONLY.
2. QUICK-DISCONNECT CAM AND GROOVE FITTINGS SHALL BE BRASS RATED AT 150 PSI AND IN ACCORDANCE WITH US MILITARY SPECIFICATIONS MIL-C-27487/US FEDERAL STANDARD A-A-59326.
3. RESTRAIN ALL JOINTS FROM MJ TEE TO 4"-90 FLANGED BEND WITH WEDGE ACTION RESTRAINER GLANDS, SEE SPECIFICATIONS.
4. COMPACT BACKFILL AND AGGREGATE BASE AS STRUCTURAL FILL.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
Mike Harmon
Chief Engineer

STANDARD DETAIL
FIRE HOSE CONNECTION IN TRAFFIC AREAS FOR FM METER ULTRASONIC AND DETECTOR CHECK VAULT LAYOUTS

W
5.0h