



ELEVATION

NOTES:

1. FIRE HYDRANT HOSE CONNECTION SETTING FOR TRAFFIC AREAS ONLY.
2. QUICK-DISCONNECT CAM AND GROOVE FITTINGS SHALL BE BRASS RATED AT 150 PSI AND IN ACCORDANCE WITH US MILITARY SPECIFICATIONS MIL-C-27487/US FEDERAL STANDARD A-A-59326.
3. RESTRAIN ALL JOINTS FROM MJ TEE TO 4"-90 FLANGED BEND WITH WEDGE ACTION RESTRAINER GLANDS, SEE SPECIFICATIONS.
4. COMPACT BACKFILL AND AGGREGATE BASE AS STRUCTURAL FILL.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 2-26-21
Mark Hermier
Chief Engineer

STANDARD DETAIL
FIRE HOSE CONNECTION IN
TRAFFIC AREAS FOR FM METER
ULTRASONIC AND DETECTOR
CHECK PRECAST VAULT LAYOUTS

W
5.0j