



NOTE:

1. INSTALL TRACER WIRE IN 2" PVC SCH. 40 PVC WHEN NOT INSTALLED ON TOP OF PIPELINE.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
M. Hammer
Chief Engineer

STANDARD DETAIL
CONTINUITY TEST STATION
FOR AWWA C900 PVC PIPE

W
9.0