


NOTES:

1. USE ONLY DIP WITH SPECIAL INTERIOR LINING PER SPECIFICATIONS OR AWWA C900/DR21. FOR GROUTING PVC AWWA C900/DR21 SEE SPECIFICATIONS.
2. FOR SEWERS 10" AND SMALLER, PROVIDE THE FOLLOWING:
 OUTGOING SEWERS, PROVIDE 2'-0" LENGTH OF SPIGOT BY SPIGOT PIPE.
 INCOMING SEWERS, PROVIDE BELL BY SPIGOT PIPE WITH BELL EXTENDING 12" BEYOND THE MANHOLE.
3. SEE NOTES 1 THRU 9 ON DETAIL S/1.0

WASHINGTON
 SUBURBAN
 SANITARY
 COMMISSION

APPROVED: 7-7-21

 Chief Engineer

STANDARD DETAIL
 BENTONITE APPLICATION
 FOR GROUTED PIPE
 TO MANHOLE CONNECTION

S
 3.01