


NOTES:

1. LOCATE END OF EXISTING ACP WATER MAIN. VERIFY OD OF EXISTING ACP WATER MAIN, WITH OD TOLERANCES OF COUPLING MANUFACTURER BEFORE REMOVING EXISTING WATER MAIN TO BE REPLACED.
2. TO BE CUT FROM THE SAME TYPE AND SIZE OF PIPE BEING SLEEVED.

WASHINGTON SUBURBAN SANITARY COMMISSION	APPROVED: <u>7-26-21</u>  Chief Engineer	STANDARD DETAIL PIPE CLOSURE JOINT DETAIL FOR EXIST. ACP WATER MAINS	$\frac{W}{11.1}$
--	---	---	------------------