



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3237221-118-2023

MDE OFFICIAL CONTACTED: JAMES LYONS

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 03/26/2023 AT 09:14PM

WORK ORDER(S): 3237221 3237211

EST DATE AND TIME SSO BEGAN: 03/26/2023 08:12PM DURATION: 1.55 HRS  
DATE AND TIME SSO ENDED: 03/26/2023 09:45PM

SOURCE-OVERFLOWING MH MH05075111 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 10700 WEYMOUTH ST 20814  
COUNTY/PAGE/GRID: M 5285 F06 TOWN/CITY: BETHESDA

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 28 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 111N OVERFLOWING ONTO THE  
PAVEMENT, AND THE GRASSY AREA AROUND MANHOLE 111N. THE CREW  
JETTED FROM MANHOLE 110M TO 111N, A TOTAL OF 262FT, RELIEVING A  
HEAVY WIPES AND GREASE OBSTRUCTION AT 47FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER NOTICEABLE ODOR  
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
FLUSHED BACK INTO MANHOLE LIME

THE OVERFLOW ON THE STREET WAS FLUSHED BACK INTO THE MANHOLE.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY  
MONTGOMERY CO MUNICIPALITIES

THE EVENT WAS ORIGINALLY REPORTED AS 10684 WEYMOUTH STREET.

SIGNS POSTED: 2 POST DATE: 03/27/2023