



# WASHINGTON SUBURBAN SANITARY COMMISSION

## SANITARY SEWER OVERFLOW WRITTEN REPORT

3237224-118-2023

MDE OFFICIAL CONTACTED: PATRICK KAMMER

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 03/26/2023 AT 10:17PM

WORK ORDER(S): 3237224 3237219

EST DATE AND TIME SSO BEGAN: 03/26/2023 08:34PM DURATION: 3.18 HRS  
DATE AND TIME SSO ENDED: 03/26/2023 11:45PM

SOURCE-OVERFLOWING MH MH10034048 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 9727 MT PISGAH RD 20903  
COUNTY/PAGE/GRID: M 5287 D08 TOWN/CITY: OAKVIEW

CAUSE: ROOTS AND WIPES EST OVERFLOW VOLUME: 763 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 048M OVERFLOWING ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 047U TO 048M, A TOTAL OF 51FT, AND RELIEVED A HEAVY WIPES AND ROOTS OBSTRUCTION, AT 47FT; ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER DISCOLORATION  
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME RAKED AREA

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY  
MONTGOMERY CO MUNICIPALITIES

THE EVENT WAS ORIGINALLY REPORTED AS 1712 MT PISGAH RD.

SIGNS POSTED: 3 POST DATE: 03/27/2023