

*

WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3232403-109-2023

MDE OFFICIAL CONTACTED: EVELYN STARVOU

DATE: 02/28/2023 AT 02:09PM DATA CALLED IN BY: MARK A ALEXANDER

WORK ORDER(S): 3232403 3232370

EST DATE AND TIME SSO BEGAN: 02/28/2023 11:41AM DURATION: 6.57 HRS DATE AND TIME SSO ENDED: 02/28/2023 06:15PM

SOURCE-REPAIR SEWER MAIN SS20006013 WATER BODY AFFECTED-POTOMAC RIVER

CLOSEST STREET ADDRESS: 10551 MAC ARTHUR BLVD 20854 COUNTY/PAGE/GRID: M 5405 E04 TOWN/CITY: ROCKVILLE

CAUSE: STREAM EROSION EST OVERFLOW VOLUME: 394 GAL UPON ARRIVAL, THE CREW FOUND A BROKEN 8" SEWER MAIN, 50 FEET DOWN STREAM OF MANHOLE 013U, LEAKING AT APPROXIMATELY 1GPM, GOING INTO A DRAINAGE BASIN THAT ENTERS THE DULLES INTERCEPTOR. A WSSC CONTRACTOR SET UP OVER PUMPING OPERATIONS FROM MANHOLE 013U TO MANHOLE 007M, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STAT:	E WATERS:
DRY WEATHER	DISCOLORATION
NOTICEABLE ODOR	PUBLIC ACCESS
PUBLIC USE OBSERVED	VISIBLE SOLIDS, STREAM BANK

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUC-TED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

THE SEGMENT IS UNDER REPAIR AND THEREFORE CANNOT YET BE CCTV INSPECTED. THE REPORT WILL BE UPDATED UPON COMPLETION OF REPAIRS AND CCTV INSPECTION. UPDATE 04/21/2023:

REPAIRS WERE COMPLETED ON 03/16/2023. CCTV 03/22/2023; BYPASS REMOVED 03/30/2023

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

EMERGENCY CONTRACT MANAGER P.CALLAHAN IS CONFERRING WITH MNCPPC AND LOCAL ENVIRONMENTAL GROUPS TO PLAN THE REPAIR AND REMEDIATION TO CLEAN AND RESTORE THE AREA. UPDATE 04/21/2023: A WSSC CONTRACTOR BUILT AN ACCESS ROAD TO THE MAINLINE AND MADE REPAIRS. AFTER COMPLETING THE REPAIRS THE CONTRACTOR REMOVED VISIBLE DEBRIS ALONG THE STREAM BANK AND REMOVED THE ACCESS ROAD.

NOTIFICATIONS MADE: MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY MONTGOMERY CO MUNICIPALITIES

ADDRESS ORIGINALLY REPORTED AS 10500 BLK R/W MAC ARTHUR BOULEVARD.