



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3248457-118-2023

MDE OFFICIAL CONTACTED: EVELYN STRAVROU

DATA CALLED IN BY: DON O DARKO

DATE: 05/02/2023 AT 04:30PM

WORK ORDER(S): 3248457 3248404

EST DATE AND TIME SSO BEGAN: 05/02/2023 10:45AM DURATION: 2.75 HRS

DATE AND TIME SSO ENDED: 05/02/2023 01:30PM

SOURCE-OVERFLOWING MH SS08008112 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 7401 JEFFERSON CT 20784

COUNTY/PAGE/GRID: P 5410 H08 TOWN/CITY: LANDOVER HILLS

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 330 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 112M OVERFLOWING APPROXIMATELY 2 GPM, GOING INTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 017U TO 112M A TOTAL OF 203', AND HIT AND RELIEVED A HARD UNKNOWN BLOCKAGE AT 160', ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

WET WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 3 POST DATE: 05/03/2023