



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3248515-073-2023

MDE OFFICIAL CONTACTED: REGAN MARCER

DATA CALLED IN BY: JAMES V MALLORY

DATE: 05/03/2023 AT 07:30AM

WORK ORDER(S): 3248515 3248511

EST DATE AND TIME SSO BEGAN: 05/02/2023 07:36PM DURATION: 2.40 HRS

DATE AND TIME SSO ENDED: 05/02/2023 10:00PM

SOURCE-BYPASS PUMP HOSE 00200845600 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 11233 ASHLEY DR 20852

COUNTY/PAGE/GRID: M 5285 E04 TOWN/CITY: ROCKVILLE

CAUSE: DAMAGED BY GROUNDSKEEPING CREW EST OVERFLOW VOLUME: 72 GAL
UPON THE WSSC'S CONTRACTOR'S ARRIVAL, IT WAS DISCOVERED THAT A BYPASS HOSE
SET-UP FOR REPAIR WORK ON A NEARBY SEWER MAIN, HAD POSSIBLY BEEN DAMAGED
BY A GROUNDSKEEPING CREW, CAUSING THE OVERFLOW. THE CONTRACTOR REPLACED
THE HOSE, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

WET WEATHER

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE LEAK WAS ON A CONTRACTORS BYPASS SYSTEM; THEREFORE, IT IS NOT CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

RAKED AREA

VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 3 POST DATE: 05/03/2023