

Potomac Filtration Plant				
Sample date	Per- and polyfluoroalkyl substances (PFAS)	Result (ppt)	Minimum Reporting Level (ppt)	EPA Health Advisory
June, 2021	NEtFOSAA	not detected	2.0	n/a <sup>1</sup>
	NMeFOSAA	not detected	2.0	n/a <sup>1</sup>
	Perfluorobutanesulfonic acid (PFBS)	2.1	2.0	n/a <sup>1</sup>
	Perfluorodecanoic acid (PFDA)	not detected	2.0	n/a <sup>1</sup>
	Perfluorododecanoic acid (PFDoA)	not detected	2.0	n/a <sup>1</sup>
	Perfluoroheptanoic acid (PFHpA)	not detected	2.0	n/a <sup>1</sup>
	Perfluorohexanesulfonic acid (PFHxS)	not detected	2.0	n/a <sup>1</sup>
	Perfluorohexanoic acid (PFHxA)	4.7	2.0	n/a <sup>1</sup>
	Perfluorononanoic acid (PFNA)	not detected	2.0	n/a <sup>1</sup>
	Perfluorooctanesulfonic acid (PFOS)	3.2	2.0	70 ppt <sup>2</sup>
	Perfluorooctanoic acid (PFOA)	3.0	2.0	70 ppt <sup>2</sup>
	Perfluorotetradecanoic acid (PFTeDA)	not detected	2.0	n/a <sup>1</sup>
	Perfluorotridecanoic acid (PFTrDA)	not detected	2.0	n/a <sup>1</sup>
	Perfluoroundecanoic acid (PFUnA)	not detected	2.0	n/a <sup>1</sup>
	11CI-PF3OUdS	not detected	2.0	n/a <sup>1</sup>
	9CI-PF3ONS	not detected	2.0	n/a <sup>1</sup>
	DONA	not detected	2.0	n/a <sup>1</sup>
HFPODA	not detected	2.0	n/a <sup>1</sup>	

Patuxent Filtration Plant				
Sample date	Per- and polyfluoroalkyl substances (PFAS)	Result (ppt)	Minimum Reporting Level (ppt)	EPA Health Advisory
June, 2021	NEtFOSAA	not detected	2.0	n/a <sup>1</sup>
	NMeFOSAA	not detected	2.0	n/a <sup>1</sup>
	Perfluorobutanesulfonic acid (PFBS)	not detected	2.0	n/a <sup>1</sup>
	Perfluorodecanoic acid (PFDA)	not detected	2.0	n/a <sup>1</sup>
	Perfluorododecanoic acid (PFDoA)	not detected	2.0	n/a <sup>1</sup>
	Perfluoroheptanoic acid (PFHpA)	not detected	2.0	n/a <sup>1</sup>
	Perfluorohexanesulfonic acid (PFHxS)	not detected	2.0	n/a <sup>1</sup>
	Perfluorohexanoic acid (PFHxA)	2	2.0	n/a <sup>1</sup>
	Perfluorononanoic acid (PFNA)	not detected	2.0	n/a <sup>1</sup>
	Perfluorooctanesulfonic acid (PFOS)	not detected	2.0	70 ppt <sup>2</sup>
	Perfluorooctanoic acid (PFOA)	not detected	2.0	70 ppt <sup>2</sup>
	Perfluorotetradecanoic acid (PFTeDA)	not detected	2.0	n/a <sup>1</sup>
	Perfluorotridecanoic acid (PFTrDA)	not detected	2.0	n/a <sup>1</sup>
	Perfluoroundecanoic acid (PFUnA)	not detected	2.0	n/a <sup>1</sup>
	11CI-PF3OUdS	not detected	2.0	n/a <sup>1</sup>
	9CI-PF3ONS	not detected	2.0	n/a <sup>1</sup>
	DONA	not detected	2.0	n/a <sup>1</sup>
HFPODA	not detected	2.0	n/a <sup>1</sup>	

#### Defintions

ppt = parts per trillion. One part per trillion is equivalent to one drop of water in 20 olympic-sized swimming pools

Minimum Reporting Level : The lowest concentration at which an analyte can be detected in a sample and its concentration can be reported with a reasonable degree of accuracy and precision

Not Detected : A compound is either not present or present at such low concentrations that it cannot be accurately detected by the analytical method.

#### Footnotes

<sup>1</sup> n/a = not applicable. There are no known health standards for these compounds

<sup>2</sup> Health advisories are specifically for individual or combined PFOA and PFOS concentrations and do not apply to other PFAS compounds