



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3297175-118-2023

MDE OFFICIAL CONTACTED: JOHN BAKER

DATA CALLED IN BY: MARVIN BAILEY

DATE: 10/19/2023 AT 07:17PM

WORK ORDER(S): 3297175 3297134

EST DATE AND TIME SSO BEGAN: 10/19/2023 02:24PM DURATION: 3.77 HRS

DATE AND TIME SSO ENDED: 10/19/2023 06:10PM

SOURCE-OVERFLOWING MH MH04001069 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 13716 PENDLETON ST 20744

COUNTY/PAGE/GRID: P 5881 B08 TOWN/CITY: FORT WASHINGTON

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 452 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 069M OVERFLOWING APPROXIMATELY 2GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO A TRIBUTARY OF PISCATAWAY CREEK. THE CREW JETTED 3 MAINLINES FROM MANHOLE 070M TO 069M, 069M TO 068M, AND 068M TO 067M, A TOTAL OF 418', AND HIT AND RELIEVED GREASE AND WIPES AT 214', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

THIS EVENT WAS ORIGINALLY REPORTED AS 13716 R/W3 PENDLETON STREET.

SIGNS POSTED: 5 POST DATE: 10/20/2023