



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3313998-118-2024

MDE OFFICIAL CONTACTED: CHRIS SCHAFFNER

DATA CALLED IN BY: CAROLINA RUIZ DATE: 01/10/2024 AT 12:20AM

WORK ORDER(S): 3313998 3313991

EST DATE AND TIME SSO BEGAN: 01/09/2024 10:50PM DURATION: 5.83 HRS
DATE AND TIME SSO ENDED: 01/10/2024 04:40AM

SOURCE-OVERFLOWING MH MH04001011 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 14313 INDIAN HEAD HWY 20607
COUNTY/PAGE/GRID: P 5881 B09 TOWN/CITY: CLINTON

CAUSE: EXCESS FLOW EST OVERFLOW VOLUME: 700 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 011U OVERFLOWING APPROXIMATELY
2GPM ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A TRIBUTARY OF
PISCATAWAY CREEK. ONCE WINTER STORM FINN MOVED OUT OF THE AREA, THE
WATER LEVEL SUBSIDED, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
WET WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.
DUE TO WINTER STORM FINN AND THE LOCATION OF THE MANHOLE, THIS MAIN
CANNOT BE CCTV INSPECTED UNTIL THE SEGMENT IS NO LONGER SURCHARGED.
THIS REPORT WILL BE UPDATED UPON COMPLETION OF THE CCTV INSPECTION.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

THE CREW INSPECTED THE AREA AND DUE TO THE HEAVY RAIN, NO LIME WAS
NEEDED.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 11 W FARMINGTON RD.

SIGNS POSTED: 1 POST DATE: 01/10/2024