



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3314853-118-2024

MDE OFFICIAL CONTACTED: JAMES LYONS

DATA CALLED IN BY: MARVIN BAILEY DATE: 01/13/2024 AT 02:00PM

WORK ORDER(S): 3314853 3314841

EST DATE AND TIME SSO BEGAN: 01/13/2024 12:16PM DURATION: 1.90 HRS
DATE AND TIME SSO ENDED: 01/13/2024 02:10PM

SOURCE-OVERFLOWING MH MH07079113 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 7800 SCOTLAND DR 20854
COUNTY/PAGE/GRID: M 5284 E05 TOWN/CITY: POTOMAC

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 228 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 113M OVERFLOWING ONTO A GRASSY
AREA AROUND THE MANHOLE AND INTO A TRIBUTARY OF CABIN JOHN CREEK.
THE CREW JETTED FROM MANHOLE 112M TO 113M, A TOTAL OF 145', RELIEVING
A HEAVY GREASE AND WIPES OBSTRUCTION AT 90' TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

WET WEATHER NOTICEABLE ODOR
PUBLIC USE OBSERVED PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 10700BLK SEVEN LOCKS RD.

SIGNS POSTED: 2 POST DATE: 01/13/2024