



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3326493-118-2024

MDE OFFICIAL CONTACTED: CHRISTY WAGNER

DATA CALLED IN BY: BRANDON T MCCREA                      DATE: 02/02/2024 AT 04:25PM

WORK ORDER(S): 3326493    3326475

EST DATE AND TIME SSO BEGAN: 02/02/2024 02:36PM    DURATION: 2.15 HRS  
DATE AND TIME SSO ENDED: 02/02/2024 04:45PM

SOURCE-OVERFLOWING MH              MH14127126    WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 1017                      KINGS HEATHER DR                      20721  
COUNTY/PAGE/GRID: P 5532 D06              TOWN/CITY: MITCHELLVILLE

CAUSE: GREASE AND WIPES                      EST OVERFLOW VOLUME: 129 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 126M OVERFLOWING APPROXIMATELY  
1GPM ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM  
MANHOLE 115U TO 125M, A TOTAL OF 95FT, AND HIT AND RELIEVED A HEAVY  
GREASE AND WIPES OBSTRUCTION, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER                      NOTICEABLE ODOR  
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT              PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2    POST DATE: 02/03/2024