



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3326821-118-2024

MDE OFFICIAL CONTACTED: E STAVRO

DATA CALLED IN BY: PARIS S JORDAN

DATE: 02/05/2024 AT 04:07PM

WORK ORDER(S): 3326821 3326700

EST DATE AND TIME SSO BEGAN: 02/05/2024 09:14AM DURATION: 4.80 HRS
DATE AND TIME SSO ENDED: 02/05/2024 02:02PM

SOURCE-OVERFLOWING MH MH08003003 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 4623 RED HAWK TER 20710
COUNTY/PAGE/GRID: P 5410 E08 TOWN/CITY: BLADENSBURG

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 1,440 GAL
UPON ARRIVAL, THE CREW FOUND MH#003M OVERFLOWING ONTO THE SURROUNDING GRASSY AREA AND INTO A NEARBY CREEK THAT OUTFALLS IN THE NORTHEAST BRANCH. THE CREW JETTED FROM MH#002M TO MH#003M, A TOTAL OF 360', AND RELIEVED GREASE AND ROOTS AT 35' TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

LIME WAS APPLIED ON IMPACTED GRASS AREAS.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 8 POST DATE: 02/05/2024