



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3341402-118-2024

MDE OFFICIAL CONTACTED: JAMES LYONS REF#156218

DATA CALLED IN BY: CAROLINA RUIZ DATE: 03/22/2024 AT 08:50PM

WORK ORDER(S): 3341402 3341398

EST DATE AND TIME SSO BEGAN: 03/22/2024 07:31PM DURATION: 2.48 HRS
DATE AND TIME SSO ENDED: 03/22/2024 10:00PM

SOURCE-OVERFLOWING MH MH05118055 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 12806 TURKEY BRANCH PKW 20853
COUNTY/PAGE/GRID: M 5165 G10 TOWN/CITY: ROCKVILLE

CAUSE: WIPES EST OVERFLOW VOLUME: 446 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 055M OVERFLOWING APPROXIMATELY 3GPM, GOING ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A NEARBY STORM DRAIN THAT OUTFALLS IN ROCK CREEK. THE CREW JETTED FROM 009U TO 055M A TOTAL OF 247', AND HIT AND RELIEVED A WIPES BLOCKAGE AT 143', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
WET WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
RAKED AREA LIME

THE CREW RAKED AND SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 4 POST DATE: 03/23/2024