



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3342743-118-2024

MDE OFFICIAL CONTACTED: NIKKI MCGUIRE

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 03/31/2024 AT 06:43PM

WORK ORDER(S): 3342743 3342742

EST DATE AND TIME SSO BEGAN: 03/31/2024 05:53PM DURATION: 2.12 HRS
DATE AND TIME SSO ENDED: 03/31/2024 08:00PM

SOURCE-OVERFLOWING MH MH14072164 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 2800 MEDSTEAD LN 20772
COUNTY/PAGE/GRID: P 5653 C04 TOWN/CITY: UPPER MARLBORO

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 127 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 164M OVERFLOWING 1GPM ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW REMOVED 30 GALLONS OF ROOTS FROM MANHOLE 065M, AND JETTED FROM MANHOLE 065M TO 164M A TOTAL OF 54', AND HIT AND RELIEVED A GREASE AND ROOTS BLOCKAGE AT 1', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 03/31/2024