



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3364915-118-2024

MDE OFFICIAL CONTACTED: NIKKI MCGUIRE #158398

DATA CALLED IN BY: CAROLINA RUIZ DATE: 05/21/2024 AT 05:00PM

WORK ORDER(S): 3364915 3364911

EST DATE AND TIME SSO BEGAN: 05/21/2024 04:30PM DURATION: 0.12 HRS  
DATE AND TIME SSO ENDED: 05/21/2024 04:37PM

SOURCE-OVERFLOWING MH MH05115032 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 12801-19 TWINBROOK PKW 20851  
COUNTY/PAGE/GRID: M 5165 C10 TOWN/CITY: ROCKVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 14 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 032M OVERFLOWING APPROXIMATELY  
2GPM INTO A TRIBUTARY OF ROCK CREEK, THE CREW JETTED FROM MANHOLE  
031M TO 032M, A TOTAL OF 194', AND HIT AND RELIEVED A GREASE AND  
WIPES BLOCKAGE AT 3', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION  
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIQUID SEWAGE ONLY. TOO CLOSE TO THE CREEK TO SPREAD LIME.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES  
DEP-MONTGOMERY COUNTY

ORIGINALLY REPORTED AS 13100 TWINBROOK PKW

SIGNS POSTED: 2 POST DATE: 05/22/2024