



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3364942-118-2024

MDE OFFICIAL CONTACTED: JOANNE HOHMAN

DATA CALLED IN BY: MARGARET K CEASAR

DATE: 05/21/2024 AT 07:32PM

WORK ORDER(S): 3364942 3364922

EST DATE AND TIME SSO BEGAN: 05/21/2024 05:15PM DURATION: 3.50 HRS

DATE AND TIME SSO ENDED: 05/21/2024 08:45PM

SOURCE-OVERFLOWING MH MH08056258 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 9122 BALTIMORE AVE 20740

COUNTY/PAGE/GRID: P 5288 B10 TOWN/CITY: COLLEGE PARK

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 210 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 258M OVERFLOWING 1GPM ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 054M TO 258M A TOTAL OF 230', AND HIT AND RELIEVED A HEAVY GREASE AND WIPES BLOCKAGE AT 230', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIQUID SEWAGE ONLY. NO LIME REQUIRED AT THIS LOCATION.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 05/22/2024