



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3370311-109-2024

MDE OFFICIAL CONTACTED: EVELYN STRAVOU

DATA CALLED IN BY: MARVIN BAILEY

DATE: 06/07/2024 AT 04:05PM

WORK ORDER(S): 3370311 3370264

EST DATE AND TIME SSO BEGAN: 06/07/2024 10:55AM DURATION: 10.08 HRS

DATE AND TIME SSO ENDED: 06/07/2024 09:00PM

SOURCE-REPAIR SEWER MAIN SS14152151 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 13605 KINGS ISLE CT 20721

COUNTY/PAGE/GRID: P 5532 H01 TOWN/CITY: MITCHELLVILLE

CAUSE: FORCE MAIN FAILURE EST OVERFLOW VOLUME: 605 GAL

UPON ARRIVAL, THE CREW FOUND SEWAGE SEEPING FROM THE CURB LINE, AND GOING INTO THE FRONT LAWN OF 13605 KINGS ISLE COURT AT 1 GPM. BROKEN PIPE WAS DISCOVERED ON FORCE MAIN 14152151L. A WSSC CONTRACTOR REPLACED 6' OF 1 1/4" PIPE, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION  
NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THIS EVENT OCCURRED ON A FORCE MAIN, THEREFORE, NO CCTV INSPECTION CAN BE DONE FOR THIS EVENT.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

LIME WAS SPREAD IN THE GRASSY AREA ON THE FRONT LAWN OF 13605 KINGS ISLE COURT.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 06/10/2024