



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3370444-118-2024

MDE OFFICIAL CONTACTED: AUSTIN

DATA CALLED IN BY: DIARRA K MACKALL DATE: 06/09/2024 AT 11:23AM

WORK ORDER(S): 3370444 3370441

EST DATE AND TIME SSO BEGAN: 06/09/2024 09:51AM DURATION: 6.23 HRS
DATE AND TIME SSO ENDED: 06/09/2024 04:05PM

SOURCE-OVERFLOWING MH MH07066031 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 8016 CINDY LN 20817
COUNTY/PAGE/GRID: M 5406 D01 TOWN/CITY: BETHESDA

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 374 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 031M OVERFLOWING APPROXIMATELY
5GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM
MANHOLE 031M TO 030M A TOTAL OF 208', AND HIT AND RELIEVED A GREASE
AND ROOT BLOCKAGE THROUGHOUT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER DISCOLORATION
NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 06/09/2024