



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3373586-118-2024

MDE OFFICIAL CONTACTED: NIKKI MCGUIRE #159660

DATA CALLED IN BY: ROBIN DESPANZA DATE: 06/25/2024 AT 12:49AM

WORK ORDER(S): 3373586 3373577

EST DATE AND TIME SSO BEGAN: 06/24/2024 08:32PM DURATION: 3.97 HRS
DATE AND TIME SSO ENDED: 06/25/2024 12:30AM

SOURCE-OVERFLOWING MH MH05170143 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 17201 SANDY KNOLL DR 20832
COUNTY/PAGE/GRID: M 5049 G08 TOWN/CITY: OLNEY

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 238 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 143M OVERFLOWING AT 1GPM INTO THE GRASSY AREA AROUND THE MANHOLE AND INTO A NEARBY STREAM THAT OUTFALLS INTO ROCK CREEK. MANHOLE 142U WAS ALSO FULL. THE CREW JETTED FROM MANHOLE 141U TO 142U A TOTAL OF 194', AND RELIEVED A HEAVY GREASE AND ROOTS BLOCKAGE AT 15', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER DISCOLORATION
NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
DEP-MONTGOMERY COUNTY MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 17200 SANDY KNOLLS DRIVE.

SIGNS POSTED: 3 POST DATE: 06/25/2024