



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3374350-118-2024

MDE OFFICIAL CONTACTED: EVELYN STRAVOU

DATA CALLED IN BY: MARVIN BAILEY

DATE: 06/27/2024 AT 02:55PM

WORK ORDER(S): 3374350 3374343

EST DATE AND TIME SSO BEGAN: 06/27/2024 09:00AM DURATION: 3.17 HRS

DATE AND TIME SSO ENDED: 06/27/2024 12:10PM

SOURCE-OVERFLOWING MH MH14091199 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 6800 AMBER HILL CT 20747

COUNTY/PAGE/GRID: P 5650 H02 TOWN/CITY: CAPITOL HEIGHTS

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 190 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 199M OVERFLOWING 1 GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A RETENTION POND, AS WELL AS A CREEK THAT OUTFALLS INTO WESTERN BRANCH. THE CREW JETTED FROM MANHOLE 353U TO 199M A TOTAL OF 510', AND HIT AND RELIEVED A HEAVY GREASE AND WIPES BLOCKAGE AT 390', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE, AND REMOVED ALL VISIBLE SOLIDS.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 2087 S. ADDISON ROAD

SIGNS POSTED: 4 POST DATE: 06/27/2024