



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3374897-109-2024

MDE OFFICIAL CONTACTED: PERCITA CARLSON

DATA CALLED IN BY: 4581

DATE: 07/01/2024 AT 02:15PM

WORK ORDER(S): 3374897 3374868

EST DATE AND TIME SSO BEGAN: 07/01/2024 10:04AM DURATION: 5.93 HRS
DATE AND TIME SSO ENDED: 07/01/2024 04:00PM

SOURCE-REPAIR SEWER MAIN SS10082002 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 14813 STONEGATE TER 20905
COUNTY/PAGE/GRID: M 5166 H05 TOWN/CITY: SILVER SPRING

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 356 GAL
UPON ARRIVAL, THE CREW FOUND THE SEWER MAIN LEAKING FROM A JOINT AND
ENTERING A NEARBY CREEK IN THE NORTHWEST BRANCH BASIN. A WSSC
CONTRACTOR SET UP BYPASS TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER DISCOLORATION
VISIBLE SOLIDS, IN STREAM

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE SEWER SEGMENT HAS BEEN PLACED ON BYPASS PUMPING PENDING REPAIRS.
CCTV INSPECTION WILL BE PERFORMED AFTER REPAIRS ARE COMPLETE. THIS
REPORT WILL BE UPDATED UPON COMPLETION OF REPAIRS.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 4 POST DATE: 07/01/2024