



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3376778-118-2024

MDE OFFICIAL CONTACTED: AMANDA GLASSMAN

DATA CALLED IN BY: MARGARET K CEASAR

DATE: 07/07/2024 AT 05:05AM

WORK ORDER(S): 3376778 3376774

EST DATE AND TIME SSO BEGAN: 07/07/2024 03:17PM DURATION: 1.05 HRS  
DATE AND TIME SSO ENDED: 07/07/2024 04:20PM

SOURCE-OVERFLOWING MH MH08056258 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 9122 BALTIMORE AVE 20740  
COUNTY/PAGE/GRID: P 5288 B10 TOWN/CITY: COLLEGE PARK

CAUSE: WIPES EST OVERFLOW VOLUME: 63 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 258U OVERFLOWING 1 GPM ONTO THE  
SIDEWALK AND GRASS. THE CREW JETTED FROM MANHOLE 054U TO 258U A TOTAL  
OF 230' TO RELIEVE WIPES AT 180' ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR  
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE AREA WAS DISINFECTED AND FLUSHED BACK INTO THE MANHOLE

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 07/07/2024