



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3377141-118-2024

MDE OFFICIAL CONTACTED: EVELYN E.

DATA CALLED IN BY: PARIS S JORDAN

DATE: 07/09/2024 AT 04:00PM

WORK ORDER(S): 3377141 3377112

EST DATE AND TIME SSO BEGAN: 07/09/2024 02:29PM DURATION: 1.53 HRS

DATE AND TIME SSO ENDED: 07/09/2024 04:01PM

SOURCE-OVERFLOWING MH MH13016126 WATER BODY AFFECTED-MUDDY BRANCH

CLOSEST STREET ADDRESS: 9900 SHELBURNE TER 20878

COUNTY/PAGE/GRID: M 5163 H02 TOWN/CITY: GAITHERSBURG

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 46 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 126N OVERFLOWING AT 0.5GPM, ONTO THE PAVEMENT AND INTO A STORM DRAIN THAT OUTFALLS INTO MUDDY BRANCH. MANHOLES 124M AND 123M WERE ALSO HOLDING. THE CREW JETTED FROM MANHOLE 123M TO 124M A TOTAL 196FT, AND RELIEVED A ROOTS AND GREASE BLOCKAGE AT 65FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

THE CREW WASHED DOWN THE AREA AROUND THE MANHOLE WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 07/09/2024