



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3381022-075-2024

MDE OFFICIAL CONTACTED: EVELYN STARVROU

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 07/24/2024 AT 11:55AM

WORK ORDER(S): 3381022 3380952

EST DATE AND TIME SSO BEGAN: 07/24/2024 07:18AM DURATION: 18.70 HRS

DATE AND TIME SSO ENDED: 07/25/2024 02:00AM

SOURCE-AIR REL VLV/FORCE M SS11005258 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 10100

SUNSET VIEW

20744

COUNTY/PAGE/GRID: P 5765 C10

TOWN/CITY: FORT WASHINGTON

CAUSE: DEFECTIVE MATERIAL

EST OVERFLOW VOLUME:

224 GAL

UPON ARRIVAL, THE CREW FOUND SEWAGE LEAKING IN THE FRONT YARD. THE CREW CONFIRMED A 4' PORTION OF THE FORCE MAIN WAS BROKEN BETWEEN MANHOLE 278K AND 171L. THE WSSC CREW EXCAVATED AND REPLACED THE BROKEN PORTION OF THE FORCE MAIN, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THIS EVENT OCCURRED ON A FORCE MAIN, THEREFORE, NO CCTV INSPECTION CAN BE DONE FOR THIS EVENT.

CONTAMINATED SOIL HAULED AWAY. NO LIME NEEDED.

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY MUNICIPALITIES