



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3384474-075-2024

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: DIARRA K MACKALL

DATE: 08/07/2024 AT 02:20PM

WORK ORDER(S): 3384474 3384446

EST DATE AND TIME SSO BEGAN: 08/07/2024 12:00PM DURATION: 7.00 HRS

DATE AND TIME SSO ENDED: 08/07/2024 07:00PM

SOURCE-AIR REL VLV/FORCE M SS15999052 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 19321 JERUSALEM RD 20837

COUNTY/PAGE/GRID: M 5044 F05 TOWN/CITY: POOLESVILLE

CAUSE: DAMAGED BY OTHERS EST OVERFLOW VOLUME: 84 GAL

UPON ARRIVAL, THE CREW DISCOVERED A BREAK ON A PRESSURE SEWER,
LEAKING 0.2 GPM, ONTO THE GRASSY AREA AROUND THE BREAK. THE BREAK WAS
CAUSED BY AN I-BEAM FROM A NEWLEY INSTALLED GUARD RAIL SYSTEM. THE
CREW DUG UP THE AREA AND REPLACED 5' OF 2" PVC, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THIS EVENT OCCURRED ON A FORCE MAIN, THEREFORE, NO CCTV INSPECTION CAN
BE DONE FOR THIS EVENT.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

GRADING OF AREA VISIBLE SOLIDS REMOVED

THE CREW REMOVED THE CONTAMINATED SOIL AND GRADED THE AREA.

NOTIFICATIONS MADE:

DEP-MONTGOMERY COUNTY

MD DEPARTMENT OF ENVIRONMENT

MONTGOMERY CO MUNICIPALITIES