



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3389183-109-2024

MDE OFFICIAL CONTACTED: EVELYN STRADAU

DATA CALLED IN BY: MARVIN BAILEY

DATE: 08/28/2024 AT 02:15PM

WORK ORDER(S): 3389183 3388946

EST DATE AND TIME SSO BEGAN: 08/27/2024 05:56PM DURATION: 52.07 HRS

DATE AND TIME SSO ENDED: 08/29/2024 10:00PM

SOURCE-REPAIR SEWER MAIN SS08033014 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 6271 67TH CT 20737

COUNTY/PAGE/GRID: P 5410 F06 TOWN/CITY: RIVERDALE

CAUSE: DEFECTIVE MATERIAL EST OVERFLOW VOLUME: 3,124 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLES 014M AND 013M LEAKING FROM THE CONE AND FOUNDATION, A TOTAL OF 1 GPM, INTO A CULVERT THAT OUTFALLS INTO NORTHEAST BRANCH. A WSSC CONTRACTOR SET-UP BYPASS PUMPING OPERATION, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE SEWER SEGMENT HAS BEEN PLACED ON BYPASS PUMPING PENDING REPAIRS. CCTV INSPECTION WILL BE PERFORMED AFTER REPAIRS ARE COMPLETE. THIS REPORT WILL BE UPDATED UPON COMPLETION OF REPAIRS.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIQUID SEWAGE ONLY. NO GRASSY AREAS AFFECTED.

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 5 POST DATE: 08/28/2024