



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3393953-118-2024

MDE OFFICIAL CONTACTED: KELLY KITCHENS

DATA CALLED IN BY: PATRICIA A HILL

DATE: 09/11/2024 AT 10:25PM

WORK ORDER(S): 3393953 3393920

EST DATE AND TIME SSO BEGAN: 09/11/2024 05:16PM DURATION: 5.73 HRS

DATE AND TIME SSO ENDED: 09/11/2024 11:00PM

SOURCE-OVERFLOWING MH MH05103069 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 4600 STONELEIGH CT 20852

COUNTY/PAGE/GRID: M 5285 F02 TOWN/CITY: ROCKVILLE

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 344 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 069M OVERFLOWING 1GPM, INTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 055U TO 069M A TOTAL OF 148', AND HIT AND RELIEVED ROOTS AND GREASE AT 50', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 09/12/2024