



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3394649-109-2024

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: DIARRA K MACKALL DATE: 09/16/2024 AT 12:35PM

WORK ORDER(S): 3394649 3394648

EST DATE AND TIME SSO BEGAN: 09/16/2024 11:15AM DURATION: 6.25 HRS  
DATE AND TIME SSO ENDED: 09/16/2024 05:30PM

SOURCE-REPAIR SEWER MAIN SS11043018 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 3601-3707 SILVER PARK DR 20746  
COUNTY/PAGE/GRID: P 5649 K06 TOWN/CITY: SUITLAND

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 750 GAL  
WHILE PERFORMING PREVENTIVE MAINTENANCE, A WSSC CREW DISCOVERED A  
BROKEN SECTION OF THE SEWER MAIN, LEAKING AT 2GPM, INTO A STREAM THAT  
OUTFALLS INTO THE BROAD CREEK BASIN. A WSSC CONTRACTOR SET UP BYPASS  
PUMPING OPERATIONS FROM MANHOLE 018U TO 017M, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER DISCOLORATION  
NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE SEWER SEGMENT HAS BEEN PLACED ON BYPASS PUMPING PENDING REPAIRS.  
CCTV INSPECTION WILL BE PERFORMED AFTER REPAIRS ARE COMPLETE. THIS  
REPORT WILL BE UPDATED UPON COMPLETION OF REPAIRS.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES  
DEP-MONTGOMERY COUNTY

ORIGINALLY REPORTED AS 3706 ST. BARNABAS ROAD.

SIGNS POSTED: 6 POST DATE: 09/17/2024