



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3398244-118-2024

MDE OFFICIAL CONTACTED: JORDAN RHOOMS

DATA CALLED IN BY: PARIS S JORDAN

DATE: 09/21/2024 AT 04:30PM

WORK ORDER(S): 3398244 3398236

EST DATE AND TIME SSO BEGAN: 09/21/2024 01:59PM DURATION: 2.60 HRS

DATE AND TIME SSO ENDED: 09/21/2024 04:35PM

SOURCE-OVERFLOWING MH MH14036093 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 10207 WELSHIRE DR 20772

COUNTY/PAGE/GRID: P 5767 H01 TOWN/CITY: UPPER MARLBORO

CAUSE: ROOTS EST OVERFLOW VOLUME: 312 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 093U OVERFLOWING ONTO THE PAVEMENT, AND INTO A STORM DRAIN THAT OUTFALLS INTO THE WESTERN BRANCH BASIN. THE CREW JETTED FROM MANHOLE 061M TO 093U, A TOTAL OF 181', AND RELIEVED A HEAVY ROOT BLOCKAGE AT 175FT, TO END THE EVENT. THE CREW ALSO REMOVED 80 GALLONS OF ROOTS FROM MANHOLE 093U.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

NOTICEABLE ODOR PUBLIC ACCESS
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE CREW WASHED DOWN THE AREA WITH DECHLORINATED WATER AND FLUSHED POOLED LIQUIDS BACK INTO THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES
PG COUNTY HEALTH DEPT

SIGNS POSTED: 2 POST DATE: 09/21/2024