



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3398859-118-2024

MDE OFFICIAL CONTACTED: NICKY

DATA CALLED IN BY: PATRICIA A HILL DATE: 09/25/2024 AT 10:00PM

WORK ORDER(S): 3398859 3398858

EST DATE AND TIME SSO BEGAN: 09/25/2024 09:12PM DURATION: 2.30 HRS  
DATE AND TIME SSO ENDED: 09/25/2024 11:30PM

SOURCE-OVERFLOWING MH MH08053036 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 8600 BALTIMORE AVE 20740  
COUNTY/PAGE/GRID: P 5410 A01 TOWN/CITY: COLLEGE PARK

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 414 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 036U OVERFLOWING 3GPM, ONTO THE PAVEMENT AND INTO A STORM DRAIN THAT OUTFALLS INTO THE NORTHEAST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 035U TO 036U A TOTAL OF 183', AND HIT AND RELIEVED A GREASE, AND WIPES BLOCKAGE, AS WELL AS A BRICK IN THE CHANNEL OF MANHOLE 036U, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER DISCOLORATION  
NOTICEABLE ODOR PUBLIC ACCESS  
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
RAKED AREA VISIBLE SOLIDS REMOVED

THE CREW REMOVED VISIBLE SOLIDS, AND WASHED DOWN THE AREA WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:  
PG COUNTY HEALTH DEPT PG COUNTY MUNICIPALITIES  
MD DEPARTMENT OF ENVIRONMENT

ORIGINALLY REPORTED AS 4703 BERWYN ROAD.

SIGNS POSTED: 2 POST DATE: 09/26/2024