



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3399771-109-2024

MDE OFFICIAL CONTACTED: KELLY KICHTEN

DATA CALLED IN BY: PARIS S JORDAN

DATE: 09/30/2024 AT 06:00PM

WORK ORDER(S): 3399771 3399710

EST DATE AND TIME SSO BEGAN: 09/29/2024 06:14PM DURATION: 31.02 HRS  
DATE AND TIME SSO ENDED: 10/01/2024 01:15AM

SOURCE-REPAIR SEWER MAIN SS11044008 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 3705 SWANN RD 20746  
COUNTY/PAGE/GRID: P 5650 B07 TOWN/CITY: SUITLAND

CAUSE: STREAM EROSION EST OVERFLOW VOLUME: 3,722 GAL  
UPON ARRIVAL, THE CREW FOUND A PORTION OF BROKEN PIPE WITHIN  
SEWER SEGMENT 008S, LEAKING DIRECTLY INTO A TRIBUTARY OF HENSON  
CREEK. A WSSC CONTRACTOR SET-UP BYPASS PUMPING OPERATIONS FROM  
MANHOLE 008M TO 006M, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
WET WEATHER DISCOLORATION

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THIS LINE IS CURRENTLY UNDER REPAIR AND IS THEREFORE NOT CCTVABLE.  
THIS REPORT WILL BE UPDATED UPON COMPLETION OF REPAIRS.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIQUID SEWAGE ONLY. NO VISIBLE SOLIDS, NO GRASSY AREA AFFECTED.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES  
PG COUNTY HEALTH DEPT

ORIGINALLY REPORTED AS 4025 TROY RD.

SIGNS POSTED: 6 POST DATE: 09/30/2024