



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3405321-118-2024

MDE OFFICIAL CONTACTED: EVELYN STAUROY

DATA CALLED IN BY: PARIS S JORDAN DATE: 10/18/2024 AT 04:19PM

WORK ORDER(S): 3405321 3405300

EST DATE AND TIME SSO BEGAN: 10/18/2024 11:17AM DURATION: 6.47 HRS
DATE AND TIME SSO ENDED: 10/18/2024 05:45PM

SOURCE-OVERFLOWING MH MH05992015 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 1900 LYTTONSVILLE RD 20910
COUNTY/PAGE/GRID: M 5286 D10 TOWN/CITY: SILVER SPRING

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 1,165 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 015U OVERFLOWING 3GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A STORM DRAIN THAT OUTFALLS INTO ROCK CREEK. A WSSC CONTRACTOR SETUP BYPASS PUMPING OPERATIONS, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THIS SEWER SEGMENT IS CURRENTLY ON BYPASS, AND THEREFORE CAN NOT BE CCTV'D AT THIS TIME. THIS EVENT WILL BE UPDATED UPON COMPLETION OF REPAIRS.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE AND REMOVED VISIBLE SOLIDS.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

ORIGINALLY REPORTED AS 8635 16TH ST.

SIGNS POSTED: 5 POST DATE: 10/18/2024