



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3407952-118-2024

MDE OFFICIAL CONTACTED: JORDAN RHOMS

DATA CALLED IN BY: MARVIN BAILEY

DATE: 10/27/2024 AT 10:25PM

WORK ORDER(S): 3407952 3407951

EST DATE AND TIME SSO BEGAN: 10/27/2024 05:15PM DURATION: 3.75 HRS
DATE AND TIME SSO ENDED: 10/27/2024 09:00PM

SOURCE-OVERFLOWING MH MH09003062 WATER BODY AFFECTED-ANACOSTIA RIVER

CLOSEST STREET ADDRESS: 4001 BUCHANAN ST 20781
COUNTY/PAGE/GRID: P 5409 J09 TOWN/CITY: HYATTSVILLE

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 1,125 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 062M OVERFLOWING AT 5GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A TRIBUTARY THAT OUTFALLS IN LOWER ANACOSTIA. THE CREW JETTED FROM MANHOLE 063U THROUGH MANHOLE 062M, AND HIT AND RELIEVED AN UNKNOWN BLOCKAGE AT 115', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION DRY WEATHER
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 10 POST DATE: 10/28/2024