



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3408733-118-2024

MDE OFFICIAL CONTACTED: JORDAN

DATA CALLED IN BY: PATRICIA A HILL

DATE: 10/31/2024 AT 07:45PM

WORK ORDER(S): 3408733 3408693

EST DATE AND TIME SSO BEGAN: 10/31/2024 03:01PM DURATION: 7.65 HRS
DATE AND TIME SSO ENDED: 10/31/2024 10:40PM

SOURCE-OVERFLOWING MH MH14108292 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 16225 PICASSO PL 20716
COUNTY/PAGE/GRID: P 5533 E07 TOWN/CITY: UPPER MARLBORO

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 459 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 292M OVERFLOWING AT 1GPM ONTO THE PAVEMENT AROUND THE MANHOLE, AND INTO A NEARBY STORM DRAIN THAT OUTFALLS INTO WESTERN BRANCH. THE CREW JETTED FROM MANHOLE 249M TO 289M A TOTAL OF 114', AND HIT AND RELIEVED A BLOCKAGE AT 111', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 100 LAWNSDALE DRIVE.

SIGNS POSTED: 2 POST DATE: 10/31/2024