



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3410510-073-2024

MDE OFFICIAL CONTACTED: KELLY

DATA CALLED IN BY: PATRICIA A HILL

DATE: 11/02/2024 AT 08:58PM

WORK ORDER(S): 3410510 3410495

EST DATE AND TIME SSO BEGAN: 11/02/2024 05:26PM DURATION: 2.40 HRS
DATE AND TIME SSO ENDED: 11/02/2024 07:50PM

SOURCE-CLEAN OUT 00185630100 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 2210 E UNIVERSITY BLVD 20902
COUNTY/PAGE/GRID: P 5409 D03 TOWN/CITY: HYATTSVILLE

CAUSE: DEBRIS EST OVERFLOW VOLUME: 1,740 GAL

UPON ARRIVAL, THE CREW FOUND PROPERTY LINE CLEANOUT OVERFLOWING 10GPM, ONTO THE PAVEMENT AROUND THE MANHOLE, AND INTO A STORM DRAIN THAT OUTFALLS INTO NORTHWEST BRANCH. THE CREW JETTED FROM AN UNIDENTIFIED MANHOLE TO MANHOLE 030M A TOTAL OF 23', AND HIT AND RELIEVED A DEBRIS BLOCKAGE AT 23', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE CREW WASHED DOWN THE AREA WITH DECHLORINATED WATER AND FLUSHED POOLED SEWAGE BACK INTO THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 11/03/2024