



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3410538-118-2024

MDE OFFICIAL CONTACTED: NICKY MCGUIRE

DATA CALLED IN BY: 4581

DATE: 11/03/2024 AT 03:37PM

WORK ORDER(S): 3410538 3410530

EST DATE AND TIME SSO BEGAN: 11/03/2024 10:03AM DURATION: 3.20 HRS
DATE AND TIME SSO ENDED: 11/03/2024 01:15PM

SOURCE-OVERFLOWING MH MH10017029 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 2210 E UNIVERSITY BLVD 20783
COUNTY/PAGE/GRID: P 5409 D03 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 96 GAL
UPON ARRIVAL, THE CREW FOUND AN UNIDENTIFIED MANHOLE OVERFLOWING AT 5GPM, ONTO THE PAVEMENT AND INTO A STORM DRAIN THAT OUTFALLS INTO NORTHWEST BRANCH. THE CREW JETTED FROM THE UNIDENTIFIED MANHOLE TO MANHOLE 029M A TOTAL OF 55', AND HIT AND RELIEVED HEAVY GREASE AND WIPES AT 8FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
THE CREW WASHED DOWN THE AREA WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 2214 E UNIVERSITY BOULEVARD.

SIGNS POSTED: 2 POST DATE: 11/03/2024