



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3411649-118-2024

MDE OFFICIAL CONTACTED: KELLY KITCHENS

DATA CALLED IN BY: ELBE L DAVIS

DATE: 11/07/2024 AT 08:05PM

WORK ORDER(S): 3411649 3411657

EST DATE AND TIME SSO BEGAN: 11/07/2024 05:22PM DURATION: 1.88 HRS
DATE AND TIME SSO ENDED: 11/07/2024 07:15PM

SOURCE-OVERFLOWING MH MH07073079 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 8703 FOX HILLS TRL 20854
COUNTY/PAGE/GRID: M 5284 B06 TOWN/CITY: POTOMAC

CAUSE: ROOTS AND WIPES EST OVERFLOW VOLUME: 56 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 079U OVEFLOWING 5GPM ONTO THE GRASSY AREA AROUND THE MANHOLE.THE CREW JETTED FROM MANHOLE 073U TO 079U A TOTAL OF 325', HIT AND RELIEVED ROOTS AND WIPES AT 260', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 8710 FOX HILLS TRAIL.

SIGNS POSTED: 1 POST DATE: 11/08/2024