



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3412611-073-2024

MDE OFFICIAL CONTACTED: CHRISTY WAGNER

DATA CALLED IN BY: MARVIN BAILEY

DATE: 11/14/2024 AT 04:35PM

WORK ORDER(S): 3412611 3412634

EST DATE AND TIME SSO BEGAN: 11/14/2024 12:00PM DURATION: 1.92 HRS
DATE AND TIME SSO ENDED: 11/14/2024 01:55PM

SOURCE-CLEAN OUT SS11044031 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 3508 RANDALL RD 20746
COUNTY/PAGE/GRID: P 5650 C06 TOWN/CITY: SUITLAND

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 115 GAL
UPON ARRIVAL, THE CREW FOUND A SECTION OF BROKEN PIPE EXFILTRATING
INTO A TRIBUTARY OF BROAD CREEK, A WSSC CONTRACTOR SET-UP BYPASS
PUMPING OPERATIONS, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR VISIBLE SOLIDS, STREAM BANK

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THIS JOB IS CURRENTLY ON BYPASS PUMPING OPERATIONS, AND IS THEREFORE
NOT CCTVABLE. THIS REPORT WILL BE UPDATED WHEN THE REPAIR IS
COMPLETE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES
PG COUNTY HEALTH DEPT

SIGNS POSTED: 8 POST DATE: 11/15/2024