



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3412634-118-2024

MDE OFFICIAL CONTACTED: FELIPE HEMMING

DATA CALLED IN BY: ELBE L DAVIS

DATE: 11/14/2024 AT 06:35PM

WORK ORDER(S): 3412634 3410072

EST DATE AND TIME SSO BEGAN: 11/14/2024 12:00PM DURATION: 1.92 HRS
DATE AND TIME SSO ENDED: 11/14/2024 01:55PM

SOURCE-OVERFLOWING MH MH11044030 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 3508 RANDALL RD 20746
COUNTY/PAGE/GRID: P 5650 C06 TOWN/CITY: SUITLAND

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 115 GAL
WHILE PERFORMING ROUTINE MAINTENANCE, THE CREW DISCOVERED MANHOLE
030M OVERFLOWING APPROXIMATELY 1GPM, ONTO THE GRASSY AREA AROUND THE
MANHOLE AND INTO A NEARBY CREEK THAT OUTFALLS INTO BROAD CREEK.
THE CREW JETTED FROM MANHOLE 029M TO 030M, A TOTAL OF 311', AND
RELIEVED A GREASE/WIPES BLOCKAGE, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR VISIBLE SOLIDS, STREAM BANK

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 4900 MATHILDA LANE

SIGNS POSTED: 8 POST DATE: 11/15/2024