



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3413549-118-2024

MDE OFFICIAL CONTACTED: MRS PERCITA

DATA CALLED IN BY: ELBE L DAVIS

DATE: 11/19/2024 AT 04:15PM

WORK ORDER(S): 3413549 3413535

EST DATE AND TIME SSO BEGAN: 11/19/2024 02:05PM DURATION: 3.92 HRS
DATE AND TIME SSO ENDED: 11/19/2024 06:00PM

SOURCE-OVERFLOWING MH MH13016097 WATER BODY AFFECTED-MUDDY BRANCH

CLOSEST STREET ADDRESS: 9838 MAHOGANY DR 20878
COUNTY/PAGE/GRID: M 5163 H02 TOWN/CITY: GAITHERSBURG

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 470 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 097M OVERFLOWING AT 2GPM ONTO
THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 091U
TO 092M A TOTAL OF 103', AND RELIEVED A GREASE AND ROOT BLOCKAGE AT
10', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME RAKED AREA

THE CREW WASHED DOWN THE SIDEWALK AND SPREAD LIME IN THE GRASSY AREA
AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 4 POST DATE: 11/19/2024