



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3413531-118-2024

MDE OFFICIAL CONTACTED: EVELYN S.

DATA CALLED IN BY: PARIS S JORDAN DATE: 11/19/2024 AT 02:38PM

WORK ORDER(S): 3413531 3413501

EST DATE AND TIME SSO BEGAN: 11/19/2024 12:00AM DURATION: 13.08 HRS
DATE AND TIME SSO ENDED: 11/19/2024 01:05PM

SOURCE-OVERFLOWING MH MH10017028 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 2220 E UNIVERSITY BLVD 20783
COUNTY/PAGE/GRID: P 5409 E03 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE EST OVERFLOW VOLUME: 314 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 028M OVERFLOWING APPROXIMATELY
5GPM ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM
MANHOLE 027M TO 028M A TOTAL OF 410', HIT AND RELIEVED A HARD GREASE
BLOCKAGE AT 321', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME RAKED AREA
VISIBLE SOLIDS REMOVED

THE CREW REMOVED 1 GALLON OF WIPES, RAKED THE AREA, AND SPREAD LIME
IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES
PG COUNTY HEALTH DEPT

THIS EVENT WAS ORIGINALLY REPORTED AS 2230 E UNIVERSITY BOULEVARD.

SIGNS POSTED: 5 POST DATE: 11/19/2024